


NOTE:

1. SET CARSONITE "BLUE" BOUNDARY MARKER 3'-0" ABOVE FINISHED GRADE AND WITHIN 1'-6" OF VALVE BOX WHEN LOCATED IN UNDEVELOPED AREAS, AND WHERE CONCRETE OR ASPHALT MATERIALS DON'T ENCOMPASS VALVE BOX.
2. CITY EMPLOYEE SHALL REMOVE THE MARKER WHEN THE LOT HAS BEEN DEVELOPED.
3. ONLY USE VALVE BOX ON APPROVED MATERIALS LIST.
4. CITY TO PROVIDE STICKER FOR CONTRACTOR TO APPLY TO MARKER.

	<i>APPROVED</i> TRM <small>ENGINEER</small>	<i>REVISED</i> 5-25-22	ADJUSTABLE VALVE BOX DETAIL	STANDARD DETAIL 50-1
	2-1-07 <small>DATE</small>	<hr/> <hr/> <hr/>		