



NOTES:

1. FOR MANUALLY OPERATED VALVES ONLY.
2. PROVIDE #24-MESH NON-CORRODIBLE SCREEN OVER END OF VENT PIPE
3. BOLLARDS SHALL BE REQUIRED FOR PROTECTION OF VENT PIPE IF LOCATED IN RIGHT-OF-WAY. BOLLARDS SHALL BE SET IN CONCRETE AS SHOWN IN DETAIL.
4. AIR RELEASE VALVES SHALL NOT BE INSTALLED UNDER PAVEMENT OR DRIVEWAYS.

	<i>APPROVED</i>	<i>REVISED</i>	COMBINATION AIR RELEASE & VACUUM RELIEF VALVE	STANDARD DETAIL 50-4
	TRM ENGINEER	5-25-22		
	2-1-07 DATE	 		