


NOTES:

1. STAKES SPACED @ 6' MAXIMUM ON OPEN RUNS AND 3' IN DITCHES AND INSTALLED ON A SLIGHT ANGLE TOWARD THE ANTICIPATED RUNOFF SOURCE. USE 2" X 2" WOOD OR EQUIVALENT STEEL STAKES.
2. SEDIMENT FENCE MUST BE PLACED AT LEVEL EXISTING GRADE. BOTH ENDS OF THE BARRIER MUST BE EXTENDED AT LEAST 8 FEET UP SLOPE AT 45 DEGREES TO THE MAIN BARRIER ALIGNMENT.
3. ATTACH FABRIC TO UPSTREAM SIDE OF POSTS.
4. SEDIMENT MUST BE REMOVED WHEN ACCUMULATIONS REACH 1/2 THE ABOVE GROUND HEIGHT OF THE FENCE AND SHALL BE UNIFORMLY DISTRIBUTED ON THE SOURCE AREA PRIOR TO TOPSOILING.
5. ANY SECTION OF SEDIMENT FENCE WHICH HAS BEEN UNDERMINED OR TOPPED MUST BE IMMEDIATELY REPLACED WITH A ROCK FILTER OUTLET.

	APPROVED	REVISED	REINFORCED SEDIMENT FENCE (30")	STANDARD DETAIL 73-4
	TRM	_____		
	CITY ENGINEER	_____		
5-25-22	_____	_____		
DATE	_____	_____		