


NOTES:

1. CONCRETE SHALL BE USED FOR THE CONSTRUCTION OF THE TRAIL.
2. TRAIL WIDTH MAY BE REDUCED TO 8' IN AREAS DETERMINED BY THE CITY ENGINEER.
3. SAW-CUT JOINT SPACING WILL MATCH THE WIDTH OF THE SIDEWALK. JOINTS WILL BE EVERY 10' OR 8' IN SPECIAL AREAS DETERMINED BY THE CITY ENGINEER.
4. SEE SIDEWALK STANDARD DETAIL FOR ADDITIONAL REQUIREMENTS.

	<i>APPROVED</i> TRM <i>CITY ENGINEER</i>	<i>REVISED</i> 5-25-22	10' PEDESTRIAN TRAIL	STANDARD DETAIL 21-7
	2-1-07 <i>DATE</i>	 		